

FORM -V

FIRE SAFETY CERTIFICATE

(See rule -13 (3) of the Odisha Fire Prevention and Fire Safety Rules, 2017 read with Fire Prevention and Fire Safety "Amendment" Rules, 2019)

File No - 117/2020 - NGR.CIR

Certificate No - 37/NGR.CIR

Dated - 08.11.2020

Certified that the G+1 floors Educational building of B.B. Central Academy, situated Over plot no -777,778,505 & 275 at Narsinghpur, Daspalla was inspected by officer of Odisha Fire Service on 05.11.2020 in presence of authorized person of said building and it has been found to comply with the fire prevention and safety requirements in accordance with Odisha Fire prevention and fire Safety rules, 2017 and with fire safety amendment rules 2019 and its various floors are fit from fire safety point of view for occupancy or usage as noted here under against each subject to compliance to the contestations as prescribed herein below.

Ground to 1 st Floor	Usage	Class Room, Labs, Office etc (Educational purpose)
---------------------------------	-------	---

CONDITATIONS

1. Fire prevention and safety measures and appliances availability of water supplies and means of access there to etc. Provided in the building or premises should be maintained by the occupier in best repair and efficient working contestation and all times for used by the occupants or the members of the fire service or both in the event of outbreak of fire.
2. The setbacks driveway entrance gates exits, staircases, corridors and escape ways should not be changed, obstructed or modified in any way.
3. The occupier shall train al staff and occupants periodically to make them well conversant in use and operation of the fire prevention and safety measures.
4. Fire drills/ rehearsals should be organized at least once in six months by involving local fire station.
5. A photocopies of this certificate should be framed and displayed at all conspicuous places in all lobbies/ corridors in all floors of all towers/ blocks of building/premises.
6. As per the guideline issued by Govt. of Odisha Home Department Notification No. 28550/CD. Bhubaneswar Dt.28.08.2020. The owner/ occupier is required to regularize the deviations by the plan approving authority of jurisdiction as guide line issued by urban development from time to time.
7. The relaxation granted and fire safety certificate issued under the scheme shall not exempt the applicant from complying with the provisions under ODA act,1982 and OTP and IT act 1956 and rues and regulations framed there under.

Valid up to 3 years from the date of issue

(08.11.2020 to)
07.11.2023

FIRE OFFICER
NAYAGARH (ODISHA)

FIRE OFFICER
NAYAGARH (ODISHA)

To
The Princial
Bharat Bikash Central Academy,
At-Daspalla, Po- Daspalla
Distt. Nayagarh (Odisha)
PIN -7520

Smishra
Principal
BB Central Academy
Daspalla, Nayagarh

MANAGER
B.B. Central Academy
Daspalla